

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated.

It is certified that an inspection team headed by Mr. Padam Singh, chemist UJS

(Name of Officers with designation) from UJS, Lab Rishikesh PHED

inspected the Premise of Reading Rainbows School

(Name & Address of the school) on 06/02/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no 152/2026/SCH-Feb-01 dated 06/02/2026

of Sub Divisional Water Quality Lab  
Uttarakhand Jal Sansthan Rishikesh (PHED Lab) certified that

the Reading Rainbows School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 06/02/2027

  
उत्तराखण्ड जल संस्थान  
रिषिकेश

Signature with Seal:

Name

Mr. Padam Singh

Designation

Chemist, UJS, Lab Rishikesh

Name & Address of the Office / Department:

To Reading Rainbows School

Shyampur, Rishikesh

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies





"NABL Recognized  
Sub Divisional water Quality Testing and Monitoring Laboratory,  
Rishikesh

Government Drinking Water Testing Laboratory"

Ph (O): 0135 - 2430239, E-mail: ujslabrshikesh@gmail.com

Test Report ID: Report No. 152/UJS/SDWQTML/RK/2025-26

Dated: 06/02/2026

Name and Address of Organization/  
Customer

**Reading Rainbows School, Rishikesh**

Product Description (Surface  
Water/ Ground Water/ Drinking  
Water)

Drinking Water

Sample Description

One Water Sample Collected from  
**Reading Rainbows School,  
Garhi Shyampur, Rishikesh**

Reference Sample Identification:

SDWQTMLUJS\_2026/SCH-Feb-01

Date of Start of Analysis: 05/02/2026

Date of End of Analysis: 06/02/2026

Date and Time of Sample Received: 05/02/2026 & 10:40 AM

Sample Collected

Harendra Singh

by:

**WATER QUALITY TEST REPORT**

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH	7.17	6.5 to 8.5	No Relaxation	IS 3025 Pt-11: 2017
2.	Total Dissolved Solids (TDS), mg/L	288	500	2000	IS 3025 Pt-16: 2017
3.	Turbidity, NTU	Less than 1	1	5	IS 3025 Pt-10: 2017
4.	Total Alkalinity (as CaCO <sub>3</sub> ), mg/L	144	200	600	IS 3025 Pt-23: 2019
5.	Total Hardness (as CaCO <sub>3</sub> ), mg/L	162	200	600	IS 3025 Pt-21: 2002
6.	Calcium (as Ca), mg/L	44	75	200	IS 3025 Pt-40: 2019
7.	Magnesium (as Mg), mg/L	28.61	30	100	APHA 23rd Ed.-3500-Mg B: 2017
8.	Chloride, mg/l	18	250	1000	IS 3025 Pt-32: 2019
	Colour, Hazen	3	5	15	IS 3025 Pt-04: 2021
10.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 Pt-05: 2018
11.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 Pt-08: 2012
12.	Total Coliform MPN/100 ml	Absent	Absent	Absent	APHA 23rd Ed-9223-B
13.	E. Coli, MPN/100 ml	Absent	Absent	Absent	APHA 23rd Ed-9223-B

1. The results listed refer only to tested sample and applicable parameters.

2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.

3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.

4. Result apply to the sample as received.

5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer.

उत्तराखण्ड जल संस्थान  
 रूचिकेश  
 Prepared By  
 (P. D. Singh)  
 UJS Lab



Reading Rainbows School  
Shyampur, Rishikesh  
Distt. Dehradun, U.K.

Authorized By  
 Authorized Signatory  
 SDWQTML, Rishikesh  
 (Swati Rana  
 UJS, Rishikesh Lab. Ind.)